



Capital Projects and Engineering Department
Churchill County Administrative Complex, Suite 190
155 N. Taylor Street, Fallon, NV 89406 – 2748
Tel: 775 423 2153, Fax: 775 423 9102

RECEIVED

JUN 30 2009

DEPARTMENT OF ADMINISTRATION
OFFICE OF THE DIRECTOR
BUDGET AND PLANNING DIVISION

June 25, 2009

Nevada State Clearing House
Department of Administration
209 East Musser, Room 200
Carson City, Nevada 89710

RE: Environmental Review Sewer Line Extension-Bottom Road, Churchill County

Dear Reviewer:

Churchill County is preparing an environmental review for a proposed sewer line extension from its existing lift Station on Bottom Road to Oasis Mobile Home Park. Churchill County is seeking federal funding from Nevada Division of Environmental Protection and the Commission on Economic Development (CDBG). In 2006 Churchill County completed construction of a new wastewater collection and treatment system. The existing sewage collection and treatment system has already undergone environmental review by USDA and US Army Corps of Engineers. .

Proposed Action

Churchill County will install approximately 6,100 feet of 12" CDR35 gravity sewer line to the County's existing lift station at Bottom Road. The County will also install approximately 20 manholes. The purpose of the project is to connect Oasis Mobile Home Park to the County's sewer collection system. The mobile home park is located southwest of the City of Fallon along Bottom Road (See Attached Figure). Much of the proposed project is located within existing public rights of way or a Truckee Carson Irrigation District easement.

All project components are underground. The aforementioned streets will be repaved once the sewer line is installed. All sewage collected by this system is treated in Churchill County's wastewater reclamation facility.

Please evaluate the proposed action to determine potential impacts to resources under your authority. Please return this letter with the enclosed envelope by July 31, 2009. If you have any questions concerning this request, please call me at 775-423-2153.

Sincerely,



Misha Stojicevic
Churchill County Capital Projects and Engineering Manager
155 North Taylor St.
Fallon, NV. 89406

The Proposed Sewer Line Extension:

_____ will

_____ will not

adversely impact environmental resources in the project area. Please include any required mitigation.

Signature

Title Date

Oasis Mobile Home Park Sewer Connection

Sewer Alpha from
Oasis Mobile Home Park to
Bottom RD Lift Station
12.1 inch Diameter SDR Pipe, L = 1.2 miles

Legend

- Lift Station
- SEWER, MAIN ROUTE
- Churchill Roads
- State
- County
- City
- Navy
- Tribal
- Private/Other
- Property Lines
- Original Construction Age
 - Not Built
 - 90 Years or Older
 - 90 Years or Newer

Oasis Mobile Home Park

